

The House: Theory vs. Practice


BEFORE PANEL SUPPORTS SEALED



AFTER PANEL SUPPORTS SEALED



Eliminate Thermal Bridging



Eliminate Thermal Bridging

(This page displays the sums of the monthly method over the heating period)

Climate: **NY, New York**
 Building:
 Spec. Capacity: **19** BTU/(ft²°F)
 Interior temperature: **68** °F
 Building type:
 Treated floor area A_{TFA}: **189,012** ft²

Building assembly	Temperature zone	Area ft ²	R-Value hr.ft ² .F/BTU	Month. red. fac.	G _i F.day/yr	kBTU/yr	per ft ² treated floor area	
Exterior wall - Ambient	A	91719	23.6	1.00	5673	528826	2.80	
Roof/Ceiling - Ambient	A	10972	34.2	1.00	5673	43631	0.23	
Floor slab / Basement ceiling	B	10788	3.6	1.00	708	51051	0.27	
Windows	A	30231	4.2	1.00	5673	977446	5.17	
Exterior door	A	600	28.0	1.00	5673	2917	0.02	
Exterior TB (length/ft)	A	18904	0.041	1.00	5673	106418	0.56	
Transmission heat losses Q_T						Total	1710290	9.05

= 6 % of the total heat loss through the facade.

Thermal bridge inputs

Nr.	Thermal bridge description	Group Nr.	Assigned to group	Qty	User deter-mined length [ft]	Length l [ft]	Input of thermal bridge heat loss coefficient BTU/hr.ft.F	Ψ BTU/hr.ft.F
6	Wall Panel Bridges						Wall Panel Bridges	
7	Panel to panel (H1)	15	Thermal bridges Ambient	1	8131.80	8131.80	Panel to panel (H1)	0.072
8	Panel corner	15	Thermal bridges Ambient	2	253.00	506.00	Panel corner	-0.038
9	Shallow over Deep (SO)	15	Thermal bridges Ambient	1	3949.50	3949.50	Shallow over Deep (SO)	0.012
10	Deep over shallow (S)	15	Thermal bridges Ambient	1	3949.50	3949.50	Deep over shallow (S)	0.015
11	Vertical Joint (V1)	15	Thermal bridges Ambient	1	1828.78	1828.78	Vertical Joint (V1)	0.029
12								
13	Roof Bridges						Roof Bridges	
14	TB1	15	Thermal bridges Ambient	1	7.58	7.58	TB1	0.099
15	TB2	15	Thermal bridges Ambient	1	207.22	207.22	TB2	0.136
16	TB3	15	Thermal bridges Ambient	1	24.27	24.27	TB3	0.072
17	TB4	15	Thermal bridges Ambient	1	24.27	24.27	TB4	0.087
18	TB6	15	Thermal bridges Ambient	1	23.84	23.84	TB6	0.021
19	TB7	15	Thermal bridges Ambient	1	23.84	23.84	TB7	0.130
20	TB8	15	Thermal bridges Ambient	1	70.24	70.24	TB8	0.143
					Total : 18,904			

The House: Heating & Cooling




Evaporator




North Side Refrigerant

South Side Refrigerant




Condenser

Sendero Verde: Heating & Cooling



Vertical Reveal Grille



Lessons Learned



Ventilation


BALANCED VENTILATION WITH HEAT RECOVERY CENTRAL SYSTEMS

■ Fresh Air

■ Exhaust Air


THE
HOUSE

CENTRAL:
RISER PER UNIT




SENDERO
VERDE
BLDG A

CENTRAL:
MAIN RISER




Ventilation: Horizontal Distribution

■ Fresh Air




THE HOUSE




SENDERO VERDE BLDG A

Ventilation: Individual Risers vs. Common Riser Return

- Fresh Air
- Exhaust Air



THE HOUSE




SENDERO VERDE BLDG A

Domestic Hot Water

- Hot water used for drinking, food prep, sanitation, and personal hygiene
- NOT for heating, swimming pools, commercial cooking, etc.



Domestic Hot Water




PASSIVE HOUSE HIGH RISE: NYC

Most Common Mid & Highrise: Central Gas w/Recirculation



Individual Riser Recirculation


1. Dedicated recirculation pipe per riser
2. Automatic venting through fixtures
3. Single floor for distribution and return
4. Less distribution floors required per zone
5. Quickest hot water delivery
6. High energy loss due to extensive piping



Riser Diagram - Base Design

Central Recirculation

1. Common recirculation pipe
2. Individual vents per riser that require access
3. Separate distribution and collection loop located on different floors
4. Additional floor height is typically required
5. Reduction in total installed pipe and heat loss - much more energy efficient
6. Slower hot water delivery response time



Riser Diagram - Better Design

Final Blower Door Test

- Final Blower Door Test results for The House were .15 Air Change/Hour (ACH).
- Passive House requirements allow a maximum .6 ACH.



The House



Sendero Verde




425 Grand Concourse Mixed Use



- Residential
- Medical facility
- Educational facility
- Cultural facility
- Retail
- Parks comfort station

425 Grand Concourse Ground Floor Plan




425 Grand Concourse Residential Floor Plan



425 Grand Concourse

Energy Efficiency - Envelope




Envelope Efficiency Requirements

Roof	R-30
Above Grade Walls	R-20 effective
Below Grade Walls	R-10
Windows – Effective U-value	0.25 Btu/hr.ft ² .F
Glazing SHGC	0.27
Façade Air Tightness	0.08 cfm/sf-façade @ 50 Pascals

425 Grand Concourse

Energy Efficiency – Heating & Cooling

- In order to not oversize equipment
 - Utilized single “ductless” console unit to serve two rooms, where possible
 - Worked with manufacturer to allow condensing units to be overconnected
 - Worked with manufacturer to limit the capacity of the evaporator units, as needed




425 Grand Concourse

Energy Efficiency – Appliances, Plugs

- Appliances
 - All Energy Star appliances
 - Except for commercial dryers
 - No ice makers in refrigerators
- Dwelling unit plug loads are a big wild card in MF buildings
 - Energy monitoring w/ tenant dashboard proposed

Energy Star Refrigerators




Moisture Control & Affordable Housing

- Greater occupant density
- Interior moisture generation rates ↑
- All exhaust air through an H/ERV
- PH natural infiltration very low (0.03 cfm/sf. @ 10 mph wind)
 - 5 to 10 times less than typical buildings
 - Moisture must get out through ventilation air
- ERV vs HRV...

Why Care About Internal Moisture?






Dew Point Temperature

- 53°F
- 49°F
- 43°F

Individual ERV Design

- Sensible recovery efficiency = 80%
- Moisture recovery efficiency
 - Summer = 61%
 - Winter = 77%
- Code minimum vent rates
 - 0.48 ACH for dwelling units on average
 - Option to boost (1.11 ACH)



Moisture Modeling - Results


- Goal: how high will interior RH get?
 - Answer
 - Weekdays – peak conditions between 50-63%
 - Weekends – most of the day between 50-70%
- Goal: is ERV boost enough?
 - Answer
 - Does help, but not enough
 - Supplemental dehumidification required

Central ERV Design




Revised Modeling Parameters


- Output – RH of interior air in apartments @ 68°F
- Same moisture generation assumptions
- Central ventilation → air mixing of moisture generation
- Moisture recovery efficiency
 - Summer Time = 72%
 - Winter Time = 83%
- Continuous code minimum exhaust
 - 0.60 ACH for dwelling units on average



Daily Model - Winter Weekday - Mixed Air Model



Daily Model - Winter Weekend - Mixed Air Model




Low In-Unit Domestic Moisture Generation

Medium In-Unit Domestic Moisture Generation


High In-Unit Domestic Moisture Generation

Mixed Air No Wheel Slow on ERV

Daily Model - Winter Weekday - Mixed Air Model



Daily Model - Winter Weekend - Mixed Air Model



- Low In-Unit Domestic Moisture Generation
- High In-Unit Domestic Moisture Generation
- Mixed Air Model with ERV Partial Bypass
- Mixed Air No Wheel Slow on ERV
- Medium In-Unit Domestic Moisture Generation

What We Learned & Key Factors

1. Occupant density is extremely important
 - As low as 200 sf/person in 2 & 3-BR units
2. Winter-time ERV moisture transfer
 - About 70-80%
 - Summer-time efficiencies can be much lower
3. Façade exfiltration rates
 - Very low for in super-airtight construction
4. Condensation risk @ thermal weak-points in façade
 - Usually window to wall connections
5. Potentially significant utility costs for supplemental dehum.
 - \$2-\$15 per unit per month





Questions?



Thank you!

Lois B Arena, PE
larena@swinter.com