

Multifamily Ventilation 302

Tom Holmes

Remediation Specialists, Inc.

Credit(s) earned on completion of this course will be reported to **AIA CES** for AIA members.

Certificates of Completion for both AIA members and non-AIA members are available upon request.

This course is registered with **AIA CES** for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA of any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product.

Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.

Copyright Materials

This presentation is protected by US and International Copyright laws. Reproduction, distribution, display and use of the presentation without written permission of the speaker is prohibited.



Course Description

Central ventilation systems in multifamily buildings are a vital building system that often compromises overall building performance. Correcting ventilation problems can produce significant energy savings in multifamily buildings while also improving occupant comfort and health.

Central ventilation system restoration is an emerging energy retrofit that has had its bumps along the way.

This session explores the lessons learned from projects that encountered a variety of design and implementation problems along the way, but ultimately achieved good performance results.

Learning Objectives

At the end of the this course, participants will be able to:

1. Understand how to evaluate existing conditions and identify good candidates for this retrofit
2. Develop a reliable, flexible design approach to help control cost overruns and minimize change orders
3. Control implementation of the work to optimize system performance and minimize occupant inconvenience
4. Commission these systems to quantify the improvement benefits

Learning Objectives

At the end of the this course, participants will be able to:


1. Understand how to evaluate existing conditions and identify good candidates for this retrofit
2. Develop a reliable, flexible design approach to help control cost overruns and minimize change orders
3. Control implementation of the work to optimize system performance and minimize occupant inconvenience
4. Commission these systems to quantify the improvement benefits

What We Expect

The central ventilation system takes stale air from the “apartment space” into the “duct space” and expels it from the building.


- Fan on the roof draws air from the riser
- Exhausted air is drawn up the risers to the fan
- Vents in the apartments pull air to the risers
- Fresh air replaces stale air

But...



What We Find

- ✘ The fan is switched off, broken, missing its belt or otherwise not functioning properly
- ✘ The riser has gaps and holes that compete with the vents or sometimes the “duct” is missing altogether
- ✘ Air flows at the vents vary wildly, sometimes flowing *into* the apartments or changing direction with the wind
- ✘ Shaft blockages or accumulated leaks prevent lower floors from removing any air at all or send it into apartments above
- ✘ Occupants block up their vents or neglect them to the point where no flow can get through.



Identify Good Candidates

- What is the PRIMARY goal of the project?
 - ✓ Reducing energy costs?
 - ✓ Constructing a system that *actually works effectively*?
- How is the system currently operating?
- What are the complaints & known problems?
- How will we repair the system's weaknesses?
 - ✓ What *can* we do from the roof or common areas?
 - ✓ What *must* we do from inside the apartments?
 - ✓ What *can't* we really expect to accomplish here?

Identify Good Candidates

- How committed is the building?
 - ✓ Who is driving this project?
 - Owner subsidizing building upgrades?
 - Resident complaints?
 - ✓ What does building management think?
- What else is happening in the building?
 - ✓ Lots of upgrades can breed “Project Fatigue”
 - ✓ How will the work be coordinated?



What Are the Opportunities?

- Improve Energy Performance
 - ✓ Reduce heating and cooling loads by reducing the volume of air expelled from the building
 - ✓ Reduce the total kWh to operate the roof fans
- Improve *Building Performance*
 - ✓ Provide ~~code compliant~~ **effective** ventilation to occupants
 - ✓ Improve indoor air quality, reduce odors in apartments
 - ✓ Reduce odor transfer among apartments
 - ✓ Reduce risk of smoke transfer in the event of a fire

What Are the Opportunities?

- Improve Energy Performance
 - ✓ Reduce heating and cooling loads by reducing the volume of air expelled from the building
 - ✓ Reduce the total kWh to operate the roof fans
- Improve *Building Performance*
 - ✓ Provide ~~code-compliant~~ **effective** ventilation to occupants
 - ✓ Better balance building pressures to reduce odor transfer among apartments
 - ✓ Reduce risk of smoke transfer in the event of fire

Reducing Ventilation Rates

Buildings built before 2008 have higher ventilation rates

	Kitchens	Bathrooms
Pre-2008 NYC Building Code	100 CFM	50 CFM
2008 NYC Adopted IBC/ IMC	25 CFM	20 CFM
Net Reduction for <i>Continuous Ventilation</i>	(75 CFM)	(25 CFM)

Reducing Ventilation Rates

Note – These savings estimates are for “post production” energy that **doesn't** include system losses (boiler/ chiller efficiency, condensate temps, etc.)

Good Energy Candidates

- ✓ Building Heating System is...
 - Oil - \$2.99/ gallon = \$3.25 **PER YEAR** / CFM reduced
 - District Steam - \$38.50/MLB = \$5.00 **PER YEAR** / CFM reduced
 - Electricity - \$0.26/ kWh = \$11.50 **PER YEAR** / CFM reduced
 - ~ Natural Gas - \$0.49/ Therm = \$0.80 **PER YEAR** / CFM reduced
- ✓ Summer Cooling adds an extra 20% savings (by fuel type)
 - Buildings with chillers or with common area central AC
 - Buildings with PTAC units
 - Depending on fuels, cooling may offer the **greater** cost savings!



Reducing Ventilation Rates

ANNUAL Savings Opportunity Per Apartment...

	Kitchens	Bathrooms
Natural Gas @ \$0.49/ Therm	\$60	\$24
#2 Heating Oil @ \$2.99/ Gal.	\$244	\$98
District Steam @ \$38.50/ MLB	\$375	\$150
Electricity @ \$0.26/ kWh	\$863	\$338

What Are the Opportunities?

- Improve Energy Performance
 - ✓ Reduce heating and cooling loads by reducing the volume of air expelled from the building
 - ✓ Reduce the total kWh to operate the roof fans
- Improve *Building Performance*
 - ✓ Provide ~~code compliant~~ **effective** ventilation to occupants
 - ✓ Better balance building pressures to reduce odor transfer among apartments
 - ✓ Reduce risk of smoke transfer in the event of fire

Improve Building Performance

TABLE 403.3-continued
MINIMUM VENTILATION RATES

OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE IN BREATHING ZONE CFM/PERSON	AREA OUTDOOR AIRFLOW RATE IN BREATHING ZONE R_a CFM/FT ^{2a}	DEFAULT OCCUPANT DENSITY #/1000 FT ^{2a}	EXHAUST AIRFLOW RATE CFM/FT ^{2a}
Private dwellings, single and multiple Garages, common for multiple units ^b Kitchens ^b Toilet rooms and bathrooms ^g	- - - 0.35 ACH but not less than 15 cfm/person	- - - -	- - - Based upon number of bedrooms. First bedroom, 2; each additional bedroom, 1	0.75 100 cfm per car 25/100^f 20/50^f

Note that these are *minimums* for *continuous* ventilation for every apartment, even the ones on the lowest floors...

Source: 2009 IMC




Improve Building Performance

- “Energy Performance” VS “Building Performance”
 - ✓ What costs are attributable to the EIM?
 - ✓ What costs are attributable to CODE COMPLIANCE?
- Design a **necessary** project that does BOTH
 - ✓ Start with what it will take to make the system **work**
 - ✓ Refine to make it work **efficiently**
- Making it **efficient** helps **making it work** affordable

Reducing Ventilation Rates

But WAIT - the vents **already** DON'T WORK!!

- Fixing the vents is a “good thing”, but...
 - ✓ No vent flow means no energy lost, right?
 - ✓ What about what's *behind the walls*?
- When *is* the energy lost?
 - ✓ When it leaves **the building**
- Fixing the **VENTS** means fixing the **SYSTEM**
- *Start with the FANS*



Reducing Ventilation Rates

VENTILATION RISER DIAGRAM.

ALL RISERS TO BE SHEET METAL

EXHAUST FAN SCHEDULE.

E.F. No.	AREA SERVED	MODEL NO.	CFM.	S.P. "H ₂ O	H.P.	T.S.	RRM.	WHEEL DIA.	ELECTRIC DATA	R.O. SIZE	CURB T. DIM.	REMARKS.
1	toilet sk.	Greenheck CEF-D-4	600	1/8"	1/4	3515	1310	—	120/1/60			6 Fans Required.
2	"	"	650	"	"	"	"	—	"			4 Fans Required
3	"	"	720	"	"	"	"	—	"			2 Fans Required
4	"	"	760	"	"	"	"	—	"			1 Fan Required.
5	"	"	850	"	"	"	"	—	"			1 Fan Required
6	kitchen sk.	" CEF-18-4	1440	1/8"	1/4	3250	6760	—	120/1/60			10 Fans Required
7	Laundry	" SQB-14-4	1500	3/8"	1/4	4024	1060	—	120/1/60			1 Fan Required - 2 speed motor
8	Laundry Dryers	" SQB-10-4	400	3/8"	1/4	3087	1060	—	120/1/60			1 Fan Required
9	COMM. RM	" SQB-13-15	4550	1/8"	1/2				208/2/60			1 " "

NOTES.

- 1 Disconnect switches with thermal overloads under hoods
 - 2 Greenheck model ATE sound curb
 - 3 Hinged hoods with padlock and key
 4. No Backdraft dampers.
- Roof Mounted Fans Only.

Reducing Ventilation Rates

EXHAUST FAN SCHEDULE.

E.F. No.	AREA SERVED	MODEL NO	CFM.	S.P. "H ₂ O	H.P.	T.S.	R.P.M.	WHEEL DIA.	ELECTRIC DATA	A 31
1	Toilet Exh.	Greenheck CBE-12-4	600	1/8"	1/2	3515	1310	—	120/1/60	
2	"	"	650	"	"	"	"	—	"	
3	"	"	720	"	"	"	"	—	"	
4	"	"	760	"	"	"	"	—	"	
5	"	"	850	"	"	"	"	—	"	
6	Kitchen Exh.	" CBE-18-6	1480	1/2"	1/4	3250	6767	—	120/1/60	

Reducing

- Fan Selection
 - 1/4"
 - 131"
 - 5/8"
 - 600"
- Check S
 - Ob
 - ava
 - Co

CBE 10"

DRIVE COMB.	RPM	TS	CAPACITY - CFM															
			0" SP		1/8" SP		1/4" SP		3/8" SP		1/2" SP		5/8" SP		3/4" SP		1" SP	
			SONE	BHP	SONE	BHP	SONE	BHP	SONE	BHP	SONE	BHP	SONE	BHP	SONE	BHP	SONE	BHP
R-1	730	2126	619		468													
			4.7	.02	4.0	.02												
R-2	820	2126	695		563		399											
R-3	910	2126																
R-3	1000	2126																
R-3	1090	3174	7.0	.07	6.7	.08	6.3	.08	5.8	.08	5.4	.08						
			1017		931		838		740		621		268					
R-3	1200	3495	7.8	.10	7.5	.11	7.1	.11	6.7	.11	6.3	.11	5.9	.07				
			1111		102		949		860		783		650		72			
R-3	1310	3815	8	.13	8.5	.13	8.2	.14	7.8	.14	7.4	.14	7.0	.14	6.7	.09		
			1128		1050		966		881		788		694		600			
R-4	1330	3873	9.0	.13	8.7	.14	8.4	.14	8.0	.14	7.6	.14	7.2	.14				
			1144		1068		989		902		812		706					
R-4	1350	3932	9.2	.14	8.9	.14	8.6	.15	8.2	.15	7.8	.15	7.4	.15	7.0	.14		
			1161		1086		1009		923		836		733		603			

**System SP \neq 5/8" WC
Measured SP = 1/4" WC**

950 CFM


Reducing Ventilation Rates

	Cost/ CFM per Year	250 CFM per Riser	X 22 Risers
Natural Gas @ \$0.49/ Therm	\$0.80	\$200	\$4,400
#2 Heating Oil @ \$2.99/ Gal.	\$3.25	\$813	\$17,875
District Steam @ \$38.50/ MLB	\$5.00	\$1,250	\$27,500
Electricity @ \$0.26/ kWh	\$11.50	\$2,875	\$63,250

What We Expect

The central ventilation system takes stale air from the “apartment space” into the “duct space” and expels it from the building.

- Fan on the roof draws air from the riser
- Exhausted air is drawn up the risers to the fan
- Vents in the apartments pull air to the risers
- Fresh air replaces stale air



The Risers


Rooftop Curbs/ Tops of Risers

- ✓ Blockages, restrictions through the roof deck
- ✓ Failed joints or visible holes in risers
- ✓ Gaps inside the curb or between the deck and duct
- ✓ Are there even any ducts at all?



The Risers

- Risers generally come in three varieties
 - ✓ Masonry (tile) risers
 - ✓ Drywall risers
 - ✓ Sheet metal risers
- Many systems are “hybrid”, using one type for certain portions and then transitioning to another
- Transitions are *always* key leakage points



The Risers

Duct Construction: Masonry


- Weaknesses
 - ✓ Mortar joints missing or failed (leaving large gaps)
 - ✓ Connections to sheet metal transitions are generally big leakers (often in ceilings, requiring manual access)



The Risers

Duct Construction: Masonry

- Weaknesses
 - ✓ Building mods can create big holes that need manual repair
 - ✓ Many buildings with masonry risers have plaster walls, making access to ducts more challenging



The Risers

Duct Construction: Drywall

- Weaknesses
 - ✓ Often “discontinuous” (built floor to floor) with misalignments common
 - ✓ ...or shoved up against a column




The Risers

Duct Construction: Drywall

This is a hole cut into a duct we *already sealed* a month before. The staff was hunting for leaky water pipe and thought it might be around here somewhere.


The orange line to the left is a pressure reference line for the variable speed fan 4 floors above. No wonder it wouldn't commission.



The Risers

Duct Construction: Sheet Metal

- Weaknesses
 - ✓ Pricy to install (“value engineered” out of final construction)
 - ✓ Careless work at seams can still leave large gaps
 - ✓ Frequently found at transitions that are key leakage points



The Risers

- Remote Mastic Application
 - ✓ Gaps around the connection need to be less than 1"
 - ✓ If the runout extends into the riser, getting a good seal on all four sides is challenging
 - ✓ Just a 1/4" gap on the top & sides of a 6" X 6" runout will *equal* the opening size of the CAR regulator! (4.5si)



The Risers

- Aerosolized Sealant (Aeroseal®)
 - ✓ Gaps **must be** less than 1/4"
 - ✓ Pressurizes entire riser – sealant flows to every gap, sealing them as it passes through – *caution in occupied buildings!*
 - ✓ Best when used in conjunction with manual sealing and mastic
 - ✓ Possible to get leakage below 5% of total system flow




All Risers are NOT Created Equal

- ✓ Are they DUCTS or are they CHASES?
 - *Ducts* transport AIR, *Chases* transport stuff (including ducts)
- ✓ Where the holes are makes a BIG difference
 - A 2si hole at the top might be equal to a 12si hole at the bottom
- ✓ Design efficiencies need to consider what's ***practical*** for ***this building's systems***

What We Expect

The central ventilation system takes stale air from the “apartment space” into the “duct space” and expels it from the building.

- Fan on the roof draws air from the riser
- Exhausted air is drawn up the risers to the fan
- Vents in the apartments pull air to the risers
- Fresh air replaces stale air



The Boots

- Boots are a big source of leakage
 - ✓ Gaps at the apartment side can draw air from wall cavities
 - ✓ Gaps where runouts meet the risers *really* leak – and can be hard to reach to seal
 - ✓ Can easily *triple* the opening over just the CAR regulator



The Boots

- It's often better to manually seal by reaching in from the apartments
 - ✓ Pack gaps with mineral wool
 - ✓ Apply intumescent caulk or similar
 - ✓ We sometimes fabricate metal clips that allow us make a seal to the riser
 - ✓ Spray foam is *not* approved for use inside ducts, unless it is covered with an approved fire barrier



The Boots

- Sometimes the duct is so degraded that no amount of mastic, caulk or anything else can save it.
 - ✓ This is generally from past water leaks in the wet walls where many ducts live
 - ✓ This condition is often *NOT* visible from video taken inside the ducts
 - ✓ Crews need to know to look for this
 - ✓ This is a legitimate “extra”



The Vents



Manual
Vent Damper



Self-Regulating
Vent Damper (CAR)

The Vents


CAR Regulators - Limitations

- ✓ Requires minimum 50pa (0.2" wc) to operate properly
- ✓ Smaller opening “competes” more with system leakage – ***requires tighter ducts***
- ✓ Relies on pressure difference between duct and apartment, which can change significantly



The Vents

Wind Pressure on a Building



Beaufort Wind Scale

Beaufort No.	Description of wind	Observation	Wind speed			
			m/s	mph	knots	ft/min
0	Calm	Smoke rises vertically. The sea is mirror smooth.	0 - 0.15	0 - 0.3	0 - 0.5	0 - 25
1	Light Air	Direction of wind shown by smoke drift but not by vanes. Scale-like ripples on sea, no foam on wave crests.	0.15 - 2.7	0.3 - 6	0.5 - 3	25 - 525
2	Light Breeze	Wind felt on face, leaves rustle, ordinary vanes moved by wind. Short wavelets, glassy wave crests.	2.7 - 3.6	6 - 8	3 - 7	525 - 700
3	Gentle Breeze	Leaves and small twigs in constant motion, wind extends light flag	3.6 - 7.2	8 - 16	7 - 10	700 - 1400
4	Moderate Breeze	Raises dust and loose paper, small branches moved. Fairy frequent whitecaps occur.	7.2 - 8.9	16 - 20	10 - 15	1,400 - 1,800
5	Fresh Breeze	Small trees in leaf begin to sway. Moderate waves, many white foam crests.	8.9 - 12.5	20 - 28	15 - 21	1,800 - 2,500
6	Strong Breeze	Large branches in motion, whistling heard in telegraph wires. Some spray on the sea surface.	12.5 - 14.5	28 - 32	21 - 27	2,500 - 2,800
7	Moderate gale	Whole trees in motion, inconvenience felt when walking into wind. Foam on waves blows on streaks.	14.5 - 20	32 - 44	27 - 33	2,800 - 3,900
8	Gale	Twigs broken of trees, generally impeded progress. Long streaks on foam appear on sea.	20 - 22	44 - 50	33 - 40	3,900 - 4,400
9	Strong gale	Straight structural damage, e.g. slates and chimney pots removed from the roofs. High waves, crest start to roll over.	22 - 28	50 - 62	40 - 48	4,400 - 5,450
10	Storm	Trees uprooted, considerable structural damage. Exceptionally high waves, visibility affected.	28 - 31	62 - 70	48 - 55	5,450 - 6,150
11	Violent Storm	Widespread damage	31 - 37	70 - 82	55 - 63	6,150 - 7,200
12	Hurricane	Air is filled with spray and foam.	> 37	> 82	> 63	> 7,200

Lessons Learned

CAR Regulators – Will work well when...

- ✓ Overall duct systems are tight enough to hold negative pressures *along the entire riser*
- ✓ Fans have sufficient power to maintain static pressures *along entire riser*
- ✓ Regulators are not “competing” with large gaps, especially around the registers, themselves
- ✓ Open windows, windy conditions *will* influence performance of even very good systems!

Lessons Learned

Don't "Swing for the Fences" with Minimum Flow Targets

- ✓ Designs with *minimum flows* as their baseline leave no room for field conditions that result in reduced flows at the lowest floors
- ✓ Allow for 10% - 15% "fade" in air flows top to bottom in tall buildings - 35CFM at the top will be 25CFM at the bottom
- ✓ Apply the *whole code* - larger apartments = higher flows (15CFM/ occupant)

Identify Good Candidates

- How “tight” is tight?
5CFM per register? ...per floor? ... X% of total flow?
Does it matter how the ducts were constructed?
- How tall is the building? Does that affect the targets?
- How do we address restrictions at the curb? Do they need to be opened up to reduce pressure drop?
- What *are* the acceptable flows at the bottom? How do we design the overall project to achieve them?

Learning Objectives

At the end of the this course, participants will be able to:

1. Understand how to evaluate existing conditions and identify good candidates for this retrofit
2. Develop a reliable, flexible design approach to help control cost overruns and minimize change orders
3. Control implementation of the work to optimize system performance and minimize occupant inconvenience
4. Commission these systems to quantify the improvement benefits

Lessons Learned

- Existing system hadn't worked in years.
- Designed with 2 large fans, 1 per wing
- Design flow of 8,900CFM per fan
 - 6,690 from 233 vents
 - 2,230 leakage allowance (10CFM per register)
 - 13 risers, 1,800 LF of discontinuous, drywall duct
 - 350 LF of unsealed sheet metal lateral above the top story

Lessons Learned

- Large gaps at runouts to registers
- Historical water damage
- Some areas were just plain “Busted Up”



Lessons Learned

FAN	Project Design				
	Fan Flow	Vent Flow	Allowed Leakage	Leakage Percent	
B01	10,000	510	170	22.3%	
B02		510	170	22.3%	
B03		510	170	22.3%	
B04		540	180	22.3%	
B05		540	180	22.3%	
B06		510	170	22.3%	
B07		510	170	22.3%	
K01		510	170	22.3%	
K02/K03		1,020	340	22.3%	
K04		510	170	22.3%	
K05		510	170	22.3%	
K06		510	170	22.3%	
B08		10,000	510	170	22.3%
B09	510		170	22.3%	
B10	510		170	22.3%	
B11	540		180	22.3%	
B12	510		170	22.3%	
B13	510		170	22.3%	
K07/K08	1,020		340	22.3%	
K09	510		170	22.3%	
K10	510		170	22.3%	
K11/K12	1,050		350	22.3%	
K13	510		170	22.3%	
Totals	20,000		13,380	4,460	22.3%

- ✓ Two “systems”, each consisting of...
 - ✓ 220 vents
 - ✓ 11 drywall duct risers (140ft long)
 - ✓ 180ft of sheet metal ductwork above the top floor
 - ✓ One 10,000CFM roof fan
- ✓ 30CFM design flow per vent (sharp edged orifices, not CARs)
- ✓ 10CFM Leakage Allowed per vent

Lessons Learned

FAN	Project Design				Project Results				Leakage CFM (Actual vs Allowed)					
	Fan Flow	Vent Flow	Allowed Leakage	Leakage Percent	Pre Seal Leakage	Percent of Flow	Post Seal Leakage	Percent of Flow	0	100	200	300	400	
B01	10,000	510	170	22.3%	284	37.3%	15	2.0%						B01
B02		510	170	22.3%	424	55.6%	14	1.8%						B02
B03		510	170	22.3%	416	54.6%	17	2.2%						B03
B04		540	180	22.3%	310	38.4%	109	13.5%						B04
B05		540	180	22.3%	297	36.8%	109	13.5%						B05
B06		510	170	22.3%	317	41.6%	88	11.5%						B06
B07		510	170	22.3%	420	55.1%	95	12.5%						B07
K01		510	170	22.3%	380	49.8%	14	1.8%						K01
K02/K03		1,020	340	22.3%	406	26.6%	42	2.8%						K02/K03
K04		510	170	22.3%	380	49.8%	108	14.2%						K04
K05		510	170	22.3%	456	59.8%	101	13.2%						K05
K06		510	170	22.3%	415	54.4%	86	11.3%						K06
B08		10,000	510	170	22.3%	299	39.2%	14	1.8%					
B09	510		170	22.3%	283	37.1%	52	6.8%						B09
B10	510		170	22.3%	418	54.8%	86	11.3%						B10
B11	540		180	22.3%	404	50.1%	17	2.1%						B11
B12	510		170	22.3%	240	31.5%	95	12.5%						B12
B13	510		170	22.3%	368	48.3%	74	9.7%						B13
K07/K08	1,020		340	22.3%	341	22.4%	151	9.9%						K07/K08
K09	510		170	22.3%	473	62.0%	92	12.1%						K09
K10	510		170	22.3%	273	35.8%	116	15.2%						K10
K11/K12	1,050		350	22.3%	310	19.8%	126	8.0%						K11/K12
K13	510		170	22.3%	520	68.2%	253	33.2%						K13
Totals	20,000		13,380	4,460	22.3%	8,434	42.2%	1,874	9.4%					

Lessons Learned

FAN	Project Design				Project		
	Fan Flow	Vent Flow	Allowed Leakage	Leakage Percent	Pre Seal Leakage	Percent of Flow	
B01	10,000	510	170	22.3%	284	37.3%	
B02		510	170	22.3%	424	55.6%	
B03		510	170	22.3%	416	54.6%	
B04		540	180	22.3%	310	38.4%	
B05		540	180	22.3%	297	36.8%	
B06		510	170	22.3%	317	41.6%	
B07		510	170	22.3%	420	55.1%	
K01		510	170	22.3%	380	49.8%	
K02/K03		1,020	340	22.3%	406	26.6%	
K04		510	170	22.3%	380	49.8%	
K05		510	170	22.3%	456	59.8%	
K06		510	170	22.3%	415	54.4%	
B08		10,000	510	170	22.3%	299	39.2%
B09	510		170	22.3%	283	37.1%	
B10	510		170	22.3%	418	54.8%	
B11	540		180	22.3%	404	50.1%	
B12	510		170	22.3%	240	31.5%	
B13	510		170	22.3%	368	48.3%	
K07/K08	1,020		340	22.3%	341	22.4%	
K09	510		170	22.3%	473	62.0%	
K10	510		170	22.3%	273	35.8%	
K11/K12	1,050		350	22.3%	310	19.8%	
K13	510		170	22.3%	520	68.8%	
Totals	20,000		13,380	4,600	22.3%	8,434	42.2%

- ✓ After in-unit sealing *and* remote mastic application, way too leaky
- ✓ We re-entered apartments and sprayed *directly into risers* eliminating all *visible* leaks...
- ✓ Better, but still way too leaky

Lessons Learned

- ✓ Each riser was treated with Aeroseal
- ✓ Significant leakage reductions across the board
(K05 and K13 were sealed along with the large metal laterals)
- ✓ Net system leakage less than 10%

Project Results				Leakage CFM (Actual vs Allowed)					
Pre Seal Leakage	Percent of Flow	Post Seal Leakage	Percent of Flow	0	100	200	300	400	
284	37.3%	15	2.0%						B01
424	55.6%	14	1.8%						B02
416	54.6%	17	2.2%						B03
310	38.4%	109	13.5%						B04
297	36.8%	109	13.5%						B05
317	41.6%	88	11.5%						B06
420	55.1%	95	12.5%						B07
380	49.8%	14	1.8%						K01
406	26.6%	42	2.8%						K02/K03
380	49.8%	108	14.2%						K04
456	59.8%	101	13.2%						K05
415	54.4%	86	11.3%						K06
299	39.2%	14	1.8%						B08
283	37.1%	52	6.8%						B09
418	54.8%	86	11.3%						B10
404	50.1%	17	2.1%						B11
240	31.5%	95	12.5%						B12
368	48.3%	74	9.7%						B13
341	22.4%	151	9.9%						K07/K08
473	62.0%	92	12.1%						K09
273	35.8%	116	15.2%						K10
310	19.8%	126	8.0%						K11/K12
520	68.2%	253	23.2%						K13
8,434	42.2%	1,874	9.4%						



Lessons Learned

FAN	Fan Flow	Project Design		
		Vent Flow	Allowed Leakage	Allowed Percent
KEF10E	1,145	910	130	11%
ERV01	800	625	125	16%
ERV02	800	625	125	16%
TEF01E	953	700	140	15%
TEF02E	953	700	140	15%
TEF03E	953	700	140	15%
TEF04E	885	650	130	15%
TEF05E	885	650	130	15%
TEF06E	953	700	140	15%
TEF07E	953	700	140	15%
TEF08E	953	700	140	15%
TEF09E	885	650	130	15%
TEF10E	953	700	140	15%
TEF11E	953	700	140	15%
TEF12E	953	750	150	16%
TEF13E	953	700	140	15%
TEF14E	1,021	750	150	15%
Totals	15,951	11,910	2,330	14.6%

✓ 16 260ft long Drywall Ducts
(KEF10E is sheet metal)

✓ 3,250 CFM Target Reduction
(@ \$12/CFM = \$39,000/ year)

✓ 10%-15% “Head” Fan vs Vent


✓ 15% Leakage Allowance
(5cfm/ vent)

Lessons Learned

FAN	Project Design				Project Results			
	Fan Flow	Vent Flow	Allowed Leakage	Allowed Percent	Req'd Flow	Actual Leakage	Actual Percent	
KEF10E	1,145	910	130	11%	1,000	90	7.9%	
ERV01	800	625	125	16%	712	87	10.9%	
ERV02	800	625	125	16%	772	147	18.4%	
TEF01E	953	700	140	15%	781	81	8.5%	
TEF02E	953	7	129		13.5%		111	11.6%
TEF03E	953	7	107		10.5%		109	11.4%
TEF04E	885	6	107		10.5%		103	11.6%
TEF05E	885	6	107		10.5%		69	7.8%
TEF06E	953	7	1,671		10.5%		137	14.4%
TEF07E	953	7	1,671		10.5%		111	11.6%
TEF08E	953	7	1,671		10.5%		61	6.4%
TEF09E	885	6	1,671		10.5%		83	9.4%
TEF10E	953	7	1,671		10.5%		51	5.4%
TEF11E	953	700	140	15%	779	79	8.3%	
TEF12E	953	750	150	16%	866	116	12.2%	
TEF13E	953	700	140	15%	829	129	13.5%	
TEF14E	1,021	750	150	15%	857	107	10.5%	
Totals	15,951	11,910	2,330	14.6%	13,581	1,671	10.5%	

- ✓ Solid sealing results
- ✓ 660 CFM *additional* leakage reduction
(\$7,900/ year *additional savings*)
- ✓ + 8-10% More “Fan Head”
- ✓ 10.5% Net System Leakage - 28% *below target*

Lessons Learned



Cluttered Ducts - Snorkels nearly fill this duct at the bottom, impeding flows

Learning Objectives

At the end of the this course, participants will be able to:

1. Understand how to evaluate existing conditions and identify good candidates for this retrofit
2. Develop a reliable, flexible design approach to help control cost overruns and minimize change orders
3. Control implementation of the work to optimize system performance and minimize occupant inconvenience
4. Commission these systems to quantify the improvement benefits

Commissioning: The Ducts

Leak Testing Vertical Risers

- ✓ Generally tested to 50pa with all “intentional openings” (registers) sealed
- ✓ XCFM per floor, register, or similar
- ✓ 50pa with reference to *where?*

Curb reference will give artificially low leakage (limited by any restriction through the deck)

At least measure to ½ way down the riser



Commissioning: The Fans

ECM fans allow “tuning” of the system.

- ✓ Our method:
 - Tachometer for fan speed
 - Manometer for SP reading
 - Plot on the fan curve
- ✓ Quick, easy, repeatable



Commissioning: The Vents

Establish Performance Parameters

- ✓ Place unit under operating conditions

 - Close windows, doors

 - Note overall building conditions

 - Make sure the fans are operating properly

- ✓ Get a good seal/ get reliable readings

- ✓ YMMV, depending on...


 - Time of year – summer VS winter conditions

 - High winds – open windows, even in adjacent units!



Commissioning: The Vents

Wind Pressure on a Building



Beaufort Wind Scale

Beaufort No.	Description of wind	Observation	Wind speed			
			m/s	mph	knots	ft/min
0	Calm	Smoke rises vertically. The sea is mirror smooth.	0 - 0.15	0 - 0.3	0 - 0.5	0 - 25
1	Light Air	Direction of wind shown by smoke drift but not by vanes. Scale-like ripples on sea, no foam on wave crests.	0.15 - 2.7	0.3 - 6	0.5 - 3	25 - 525
2	Light Breeze	Wind felt on face, leaves rustle, ordinary vanes moved by wind. Short wavelets, glassy wave crests.	2.7 - 3.6	6 - 8	3 - 7	525 - 700
3	Gentle Breeze	Leaves and small twigs in constant motion, wind extends light flag	3.6 - 7.2	8 - 16	7 - 10	700 - 1400
4	Moderate Breeze	Raises dust and loose paper, small branches moved. Fairy frequent whitecaps occur.	7.2 - 8.9	16 - 20	10 - 15	1,400 - 1,800
5	Fresh Breeze	Small trees in leaf begin to sway. Moderate waves, many white foam crests.	8.9 - 12.5	20 - 28	15 - 21	1,800 - 2,500
6	Strong Breeze	Large branches in motion, whistling heard in telegraph wires. Some spray on the sea surface.	12.5 - 14.5	28 - 32	21 - 27	2,500 - 2,800
7	Moderate gale	Whole trees in motion, inconvenience felt when walking into wind. Foam on waves blows on streaks.	14.5 - 20	32 - 44	27 - 33	2,800 - 3,900
8	Gale	Twigs broken of trees, generally impeded progress. Long streaks on foam appear on sea.	20 - 22	44 - 50	33 - 40	3,900 - 4,400
9	Strong gale	Straight structural damage, e.g. slates and chimney pots removed from the roofs. High waves, crest start to roll over.	22 - 28	50 - 62	40 - 48	4,400 - 5,450
10	Storm	Trees uprooted, considerable structural damage. Exceptionally high waves, visibility affected.	28 - 31	62 - 70	48 - 55	5,450 - 6,150
11	Violent Storm	Widespread damage	31 - 37	70 - 82	55 - 63	6,150 - 7,200
12	Hurricane	Air is filled with spray and foam.	> 37	> 82	> 63	> 7,200

Learning Objectives

Wrap Up

At the end of the this course, participants will be able to:

1. Understand how to evaluate existing conditions and identify good candidates for this retrofit
2. Develop a reliable, flexible design approach to help control cost overruns and minimize change orders
3. Control implementation of the work to optimize system performance and minimize occupant inconvenience
4. Commission these systems to quantify the improvement benefits

This concludes The American Institute of Architects
Continuing Education Systems Course

Tom Holmes



(800) 395-8368

tholmes@rsinj.com